

UTILITY ISSUED BOIL WATER NOTICE

RECEIVED
AUG 07 2019
OEHS - WHEELING

BOIL YOUR WATER BEFORE USING

On August 7, 2019, a water problem occurred affecting Clive Avenue from Fourth Street to Dexter Avenue in Moundsville, West Virginia possibly causing contamination of your water.

The areas that are affected are as follows:

- Entire Water System or Clive Avenue from Fourth Street to Dexter Avenue
(Area of Water System)

CONDITIONS INDICATE THERE IS A HIGH PROBABILITY THAT YOUR WATER IS CONTAMINATED. TESTING IS BEING PERFORMED TO CONFIRM OR DENY THE PRESENCE OF CONTAMINATION IN YOUR WATER.

What should I do?

DO NOT CONSUME THE WATER WITHOUT BOILING IT FIRST. Bring all water to a boil, let it boil for one minute, and let it cool before using, or use bottled water. Boiled or bottled water should be used for drinking, making ice, brushing teeth, washing dishes, bathing, and food preparation **until further notice**. Boiling kills bacteria and other organisms in the water.

What happened? What is being done?

A construction crew was performing a tie-in of a new replacement main water line into the existing main water line at Clive Avenue on Eastern Fourth Street. This had affected 20 customers on Clive Avenue only. The tie-in has been completed and water service has been returned to all customers. The customers affected were notified through news media and social media of the boil order. A 48 hour boil order is in place until Coliform/Bacti sample results are received from the lab in Wheeling.

(Describe the corrective action)

We will inform you when you no longer need to boil your water. We anticipate resolving the problem within 48 hours.
(Estimated time frame)

For more information, please contact Terry Roberts at 304-280-3725
(Contact Name) (Telephone number)

or P.O. Box 480 Moundsville, WV 26041. General guidelines on ways to lessen
(Mailing Address)

the health risk are available from the EPA Safe Drinking Water Hotline at 1 (800) 426-4791.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Moundsville Water Board.
(Water System Name)

PWSID#: WV3302611

Date and time distributed: August 7, 2019 /2:30pm